

Appendix A to Subpart Q of Part 141—
NPDWR Violations and Other
Situations Requiring Public Notice ¹

Contaminant	MCL/MRDL/TT violations ²		Monitoring & testing procedure violations	
	Tier of public notice required	Citation	Tier of public notice required	Citation
1. * * *				
C. Lead and Copper Rule (Action Level for lead is 0.010 mg/L, for copper is 1.3 mg/L).				
1. Lead and Copper Rule (TT)	2	141.80 (except paragraph (c) through 141.84, 141.85(a) through (c) (except paragraphs (c)(3)), (h), and (j), and 141.93.	3	141.86 through 141.90, 141.92.

Appendix A—Endnotes

* * * * *

1. Violations and other situations not listed in this table (e.g., failure to prepare Consumer Confidence Reports), do not require notice, unless otherwise determined by the primacy agency. Primacy agencies may, at their option, also require a more stringent public notice tier (e.g., Tier 1

instead of Tier 2 or Tier 2 instead of Tier 3) for specific violations and situations listed in this Appendix, as authorized under § 141.202(a) and § 141.203(a).

2. MCL—Maximum contaminant level, MRDL—Maximum residual disinfectant level, TT—Treatment technique

* * * * *

21. Amend appendix B to subpart Q of part 141 by revising the entry for “23. Lead” under the heading “D. Lead and Copper Rule” and endnote 13 to read as follows:

Appendix B to Subpart Q of Part 141—
Standard Health Effects Language for
Public Notification

Contaminant	MCLG ¹ mg/L	MCL ² mg/L	Standard health effects language for public notification			
National Primary Drinking Water Regulations (NPDWR)						
*	*	*	*	*	*	*

D. Lead and Copper Rule

23. Lead	zero	TT ¹³	There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.
*	*	*	*

Appendix B—Endnotes

* * * * *

1. MCLG—Maximum contaminant level goal

2. MCL—Maximum contaminant level

* * * * *

13. Action Level = 0.010 mg/L

* * * * *

PART 142—NATIONAL PRIMARY
DRINKING WATER REGULATIONS
IMPLEMENTATION

22. The authority citation for part 142 continues to read as follows:

Authority: 42 U.S.C. 300f, 300g–1, 300g–2, 300g–3, 300g–4, 300g–5, 300g–6, 300j–4, 300j–9, and 300j–11.

23. Amend § 142.14 by revising paragraphs (d)(8) and (9) and (d)(10)(ii) to read as follows:

§ 142.14 Records kept by States.

(d) * * *

(8) Records of the currently applicable or most recent State determinations, including all supporting information and an explanation of the technical basis for each decision, made under the provisions of 40 CFR part 141, subpart I, listed in paragraphs (d)(8)(i) through

(xix) of this section for the control of lead and copper. For the records identified in paragraphs (d)(8)(i) through (xix), if no change is made to State determinations during a 12-year retention period, the State must retain the record until a new decision, determination, or designation has been issued.

(i) Section 141.81(b)—for any water system deemed to be optimized under § 141.81(b) of this chapter, any conditions imposed by the State on specific water systems to ensure the continued operation and maintenance of corrosion control treatment in place;